

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Neesha Kumari (Lab Attendant)

(Name of Officers with designation) from U.P. JAL NIGAM BIJNOR PHED

inspected the THE SCHOLARS VALLEY SCHOOL, DHAMPUR (BIJNOR)

(Name & Address of the school) on 13/06/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BJ/1231 dated 15/06/2026

of WATER ANALYSIS LAB JAL (PHED Lab) certified that the

THE SCHOLARS VALLEY SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 YEAR



Signature with Seal:

Name : AKSHAY KUMAR

Designation : A.E.

Name & Address of the Office / Department : UP JAL NIGAM (BIJNOR)


To

THE SCHOLARS VALLEY SCHOOL

DHAMPUR, BIJNOR

(Name & Address of the Institution)

अभियन्ता
क्षेत्र कार्यालय
10 जल निगम (प्रामीण)
बिजनौर





Analysis Report

District Level Water Analysis Laboratory U.P, Jal Nigam Bijnor


Report No. BJ/1221	Date	15-06-2026	Page No.	
Customer Details				
Office Name and Address	The Scholars Valley School			
Ref Letter No & date	Date:			
Basic details of sample				
District	Bijnor	Block	-----	
Gram Panchayat	-----	Village	-----	
Habitation	-----	Location	The Scholars Valley School	
Water Source	SUBMERSIBLE	Sample No.	BJ/1221	
Quantity of Sample	1 Lt	Date of S.C	13-06-2026	
Receiving Date	13-06-2026	Sample Collector	Neeraj Kumar	
Sample Depositor	Neeraj Kumar	Sampling Method Used	IS 17614 (Part 1):2021	
Analysis Start Date	13-06-2026	Analysis Completion date-	15-06-2026	

Environmental Condition			
Temperature	25.2°C	Relative Humidity	Upto 55.6%

S.R	Analyzed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
2	pH	7.581	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	Turbidity (NTU)	1.61	1.0	5.0	IS 3025 P-10:2023
4	TDS(mg/l)	270.0	500	2000	IS 3025 P-16:2023
5	Chloride(mg/l)	18.0	250	1000	IS 3025 P-32:2019
6	Total Alkalinity(mg/l)	200.0	200	600	IS 3025 P-23:2023
7	Total Hardness(mg/l)	240.0	200	600	IS 3025 P-21:2019
8	Calcium(mg/l)	52.09	75	200	IS 3025 P-40:2024
9	Magnesium (mg/l)	27.21	30	100	IS 3025 P-46:2023
10	Nitrate (mg/l)	1.01	45	45	Apha24 th edition -4500 NO ₃ Method B (UV Screening Method):2023
11	Sulphate (mg/l)	7.18	200	400	Apha24 th edition-4500 SO ₄ Method E (Turbidimetric Method):2023
12	Iron (mg/l)	0.08	1.0	1.0	Apha 24 th edition -3500 Fe method B (Phenanthroline Method):2023
13	Fluoride(mg/l)	0.196	1.0	1.5	Apha24th edition-4500 F Method C (Electrode method):2023
14	E.coli	0	Shall not be detectable in 100 ml sample		IS 15185:2016
15	Total Coliform	0	Shall not be detectable in 100 ml sample		IS 15185:2016

Note -

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.


prepared By: Lab Technician


Authorized Signatory
Technical Manager
(Microbiological)


Authorized Signatory
Technical Manager
(Chemical)

End of Report



Scanned with OKEN Scanner